

Official Laboratory Report

Report To: VILLAGE OF AKRON
4380 BEACH ST
AKRON MI 48701

Sample ID: LL83846
Work Order: 50803285_01

System Name/Owner: VILLAGE OF AKRON
Collection Address: 3257 JUDD, AKRON
Collected By: SHANE BILLS
Township/Well#/Section: FAIRGROVE/WELL #5/3
County: Tuscola
Sample Point: WELL TAP
Water System: Public System Well

WSSN/Pool ID: 00070
Source: TYPE I
Site Code: TP005
Collector: Other
Date Collected: 08/28/2025 16:00
Date Received: 08/29/2025 08:13
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	09/04/2025		EPA 533	763051-92-9
4:2FTS	Not Detected	ng/L	2	09/04/2025		EPA 533	757124-72-4
6:2FTS	Not Detected	ng/L	2	09/04/2025		EPA 533	27619-97-2
8:2FTS	Not Detected	ng/L	2	09/04/2025		EPA 533	39108-34-4
9CI-PF3ONS	Not Detected	ng/L	2	09/04/2025		EPA 533	756426-58-1
ADONA	Not Detected	ng/L	2	09/04/2025		EPA 533	919005-14-4
HFPO-DA	Not Detected	ng/L	2	09/04/2025	370	EPA 533	13252-13-6
NFDHA	Not Detected	ng/L	2	09/04/2025		EPA 533	151772-58-6
PFBA	Not Detected	ng/L	2	09/04/2025		EPA 533	375-22-4
PFBS	Not Detected	ng/L	2	09/04/2025	420	EPA 533	375-73-5
PFDA	Not Detected	ng/L	2	09/04/2025		EPA 533	335-76-2
PFDaA	Not Detected	ng/L	2	09/04/2025		EPA 533	307-55-1
PFEESA	Not Detected	ng/L	2	09/04/2025		EPA 533	113507-82-7
PFHpA	Not Detected	ng/L	2	09/04/2025		EPA 533	375-85-9
PFHpS	Not Detected	ng/L	2	09/04/2025		EPA 533	375-92-8
PFHxA	Not Detected	ng/L	2	09/04/2025	400000	EPA 533	307-24-4
PFHxS	Not Detected	ng/L	2	09/04/2025	51	EPA 533	355-46-4
PFMBA	Not Detected	ng/L	2	09/04/2025		EPA 533	863090-89-5
PFMPA	Not Detected	ng/L	2	09/04/2025		EPA 533	377-73-1
PFNA	Not Detected	ng/L	2	09/04/2025	6	EPA 533	375-95-1
PFOA	Not Detected	ng/L	2	09/04/2025	8	EPA 533	335-67-1
PFOS	Not Detected	ng/L	2	09/04/2025	16	EPA 533	1763-23-1
PFPeA	Not Detected	ng/L	2	09/04/2025		EPA 533	2706-90-3
PFPeS	Not Detected	ng/L	2	09/04/2025		EPA 533	2706-91-4

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Not Detected: Not detected at or above the reporting limit (RL)



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample ID: LL83846

Work Order: 50803285_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

PFUnA	Not Detected	ng/L	2	09/04/2025	EPA 533	2058-94-8
-------	--------------	------	---	------------	---------	-----------

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

**Tuscola County Health Dept.
1309 Cleaver Rd
Caro, MI 48723
989 673-8114**

RL: Reporting Limit
MCL: Maximum Contaminant Level
AL: Action Level

mg/L: milligrams / Liter (ppm)
ng/L: nanograms / Liter (ppt)
MPN: Most Probable Number

CFU: Colony Forming Unit
CAS: Chemical Abstract Service
Laboratory Contact: Marlene Kane

Not Detected: Not detected at or above the reporting limit (RL)