

Official Laboratory Report

Report To: MARVIN HASSO JR
4380 BEACH ST
AKRON MI 48701

Sample ID: LL41290
Work Order: 40901477_03

System Name/Owner: VILLAGE OF AKRON
Collection Address: 4380 BEACH ST, AKRON
Collected By: MARVIN HASSO JR
Township/Well#/Section: FAIRGROVE/#5/3
County: Tuscola
Sample Point: PLANT TAP
Water System: Public System Well

WSSN/Pool ID: 00070
Source: TYPE I
Site Code: TP005
Collector: Other
Date Collected: 09/12/2024 13:43
Date Received: 09/13/2024 09:09
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Cyanide-Available	Not Detected	mg/L	0.02	09/19/2024	0.2	ASTM D6888-04	57-12-5
Nitrate as N	Not Detected	mg/L	0.4	09/13/2024	10	NECi	14797-55-8
Nitrite as N	Not detected	mg/L	0.05	09/13/2024	1	NECi	14797-65-0

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Tuscola County Health Dept.
1309 Cleaver Rd
Caro, MI 48723
989 673-8114

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane